

## EU/UKCA Declaration of Conformity (No. 21025)

### 1. Product Identification:

Product *Smoke Alarm Device*

### 2. Manufacturer:

Name *FireAngel Safety Technology Limited*

Address *Vanguard Centre, Sir William Lyons Road, Coventry, CV4 7EZ, UK*

### EU Authorised Representative:

Name *Authorised Representative Service*

Address *77 Camden Street Lower, Dublin, D02 XE80, Ireland*

### 3. This Declaration of Conformity is issued under the sole responsibility of the Manufacturer:

### 4. Product details:

Product *Smoke Alarm Device*

Model/type *FireAngel FA6615, FA6115, FA6611, FA6111, FA6620, FA6120*

*Angeleye AE6615, AE6611, AE6620*

Description *Battery powered Smoke Alarm for domestic applications*

Specification *FA6620, FA6120, AE6620 (Sealed 3V Lithium battery), FA6615, FA6115, AE6615, FA6611, FA6111, AE6611 ( 2 x 1.5AA replaceable Alkaline batteries) optical smoke alarm*

### 5. The object of the declaration described above is in conformity with the relevant Union harmonisation legislation and UK Statutory Instruments:

### 6. Legislation and standards:

<b>UK CA</b> UK (UKCA) Legislation	<b>CE</b> EU (CE) Legislation	<b>Designed, Harmonised and other standards showing compliance</b>
<b>Construction Product Regulation 2019/465</b>	<b>Construction Products Regulation 305/2011/EU</b>	EN14604:2005/AC:2008
<b>The Electromagnetic Compatibility Regulations 2016/1091</b>	<b>The Electromagnetic Compatibility Directive 2014/30/EU</b>	EN 50130-4:2011+A1:2014 EN 61000-6-3:2007/A1:2011 /AC:2012
<b>The Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012/3032</b>	<b>The Restriction of Hazardous Substances Directive 2011/65/EU and Commission Delegated Directive (EU) 2015/863</b>	EN IEC 63000:2018

7. The notified body CNPP - Laboratoire du Feu - Service analyse, Route de la chapelle Réanville, CS 22265, 27950 Saint Marcel 1116-CPR-151 (FA6620 / FA6120 / AE6620), 1116-CPR-152 (FA6615 / FA6115 / AE6615) and 1116-CPR-153 (FA6611 / FA6111 / AE6611) in accordance to EN14604:2005+AC:2008.

The UK approved BRE Global Ltd, Bucknalls Lane, Watford, Hertfordshire, WD25 9XX. United Kingdom issued the certificate 0832-UKCA-CPR-F1385 (FA6615), 0832-UKCA-CPR-F1386 (FA6611), 0832-UKCA-CPR-F1387 (FA6620) in accordance to EN14604:2005+AC:2008

### 8. Authorisation and signature

Signed for and on behalf of: *FireAngel Safety Technology Limited*

Place of issue: *Coventry*

Date of issue: *27<sup>th</sup> January 2022*

Name: *Ian Ballinger*

Function: *Head of Certification*

Signature:

